

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. HEALTH/WATER/2025/238

Dated: 16/07/2025

It is certified that an inspection team headed by Dr WAMAN P.GENGAJE, Taluk Health Officer with Team (Name of Officers with designation) from Taluk Health Office, Panchayat Samitee Mulshi (Paud) PHED inspected the KUNJIR PUBLIC SCHOOL, MANJARI B.K., TAL HAVELI, DIST- PUNE, MAHARASHTRA (Name & Address of the school) on 16/07/2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no GIFT/Jul/2025/372 dated 15/07/2025 of GODWA INSTITUTE OF FOOD TECHNOLOGY (OPC) PRIVATE LIMITED (Food Testing Laboratory) Datta Palace, Balaji Nagar, Flat No. 17 Dhankawadi Pune Satara Road Pune 411043_(PHED Lab) certified that the KUNJIR PUBLIC SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01 (One Year).

Signature with Seal: 
Name : Dr WAMAN P.GENGAJE
Designation : Taluk Health Officer
Name & Address of the Office / Department : Taluk Health Office, Panchayat Samitee Mulshi (Paud)



To
The Manager
KUNJIR PUBLIC SCHOOL,
MANJARI B.K., TAL HAVELI, DIST-
PUNE, MAHARASHTRA
(Name & Address of the
Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**GODWA INSTITUTE OF FOOD TECHNOLOGY
(OPC) PRIVATE LIMITED (Food Testing Laboratory)**
NABL Accredited Laboratory as per ISO/IEC 17025:2017
ADDRESS: Datta Palace, Balaji Nagar, Flat No. 17
Dhankawadi Pune Satara Road Pune 411043
CONTACT : 9970066714/7720002376
EMAIL ID : godwainstitute@gmail.com



Report Date: 15/07/2025

Test Report

ULR No.:TC131452500000808F

Customer Name and Address	KUNJIR PUBLIC SCHOOL, MANJARI B.K., TAL HAVELL, DIST- PUNE, MAHARASHTRA	Test Report	GIFT/Jul/2025/372
		Laboratory Code	C/03/25/0851
Contact details	Mr. Malhari Kunjir	Mobile	7844824444
Sample Information			
Sample Name	Water	Quantity	1 ltr
Drawn by	Customer	Packing Details	Plastic Bottle
Mfg. Date	-	Batch No.	-
Best Before	-	Other Info.	-
Laboratory Analysis Information			
Performance	In House	Sample Received Date	15/07/2025
Start Date of Analysis	15/07/2025	End Date of Analysis	15/07/2025
Result Details			
Name of Group	Water	Discipline	Chemical
Sub Group	Drinking Water		

Sr. No	Parameters	Results	Unit	Specification	Method
1.	pH at 25°C	7.16	-	6.5-8.5	IS:3025 (Part-11)
2.	Colour	<0.50	CU	Max. 5.0	IS:3025 (Part-04)
3.	Odour	Agreeable	-	Agreeable	IS:3025 (Part-05)
4.	Turbidity	<0.50	NTU	Max 1.0	IS:3025 (Part-10)
5.	Total Hardness as CaCO ₃	53.00	mg/L	Max 200	IS:3025 (Part-21)
6.	Total Dissolved Solids	111.00	mg/L	Max 500	IS:3025 (Part-16)
7.	Chlorides as Cl	10.84	mg/L	Max 250	IS:3025 (Part-32)
8.	Calcium as Ca	9.35	mg/L	Max 75	IS:3025 (Part-40)
9.	Magnesium as Mg	<5.0	mg/L	Max 30	IS:3025 (Part-46)
10.	Total Alkalinity as CaCO ₃	25.20	mg/L	Max 200	IS:3025 (Part-23)
11.	Fluoride as F	<0.20	mg/L	Max 1.0	IS:3025 (Part-60)

Remark: Any additions to, deviations or exclusions from the method: No

Authorised Sign


Rajendra M. Katole
CEQ Quality Manager



Checked By
TECHNICAL MANAGER